

THIS IS A COURTESY COPY OF THIS RULE. ALL OF THE DEPARTMENT'S RULES ARE COMPILED IN TITLE 7 OF THE NEW JERSEY ADMINISTRATIVE CODE.

9. Low-lying inland areas showing signs of ponding or freshwater wetland vegetation such as skunk cabbage (*Symplocarpus foetidus*), tussock sedge (*Carex stricta*), cat-tails (*Typha* spp.), alders (*Alnus* spp.), or white cedar (*Chamaecyparis thyoides*); and

10. Flat low-lying areas adjoining streams.

#### 7:9A-4.3 Distances

The minimum separation distance between the various components of the system and the other features listed shall conform to and be maintained in accordance with Table 4.3 below. The location of a new well must be in conformance with the requirements of N.J.A.C. 7:9D. No permit or waiver issued outside of this Chapter by any local, State or Federal entity shall be construed to permit deviation from or a waiver of the separation distances requirements listed in the Table 4.3 below..

Table 4.3 Minimum Required Separation Distances (feet)

Component	Reservoir, Well or Suction Line	Water Service Line, Pressure	Water Course (1,12)	Occupied Building	Property Line (15)	Disposal Field	Existing Seepage Pit or Cesspool	In-ground Swimming pool
Building Sewer	25(2)	1	-	-	-	-	-	-
Septic Tank	50(2)	10	25(2,5)	10(6)	5	-	-	10
D-Box <sup>(14)</sup>	50(2)	10	25(2,5)	10	5	-	-	10
Disposal Field <sup>(11)</sup>	100(2,4)	10	50(2,3,5)	25(7)	10	50(8)	50	20
Seepage Pit <sup>(9)</sup>	150/100 <sup>(2,13)</sup>	25	100(2,5)	50(7)	20	50	50(10)	30
Dry Well	50	-	-	-	-	50	50	-